Impact Performance
Certification Authorization Report

PGT Industries, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-278
Company Code:	190
Certification Date:	10/8/2013
Revision No:	2
Revision Date:	4/16/2026
Expiration Date:	5/21/2029

Product Rating Information:

Model:	FD5555 Impact Door/Sidelite Mullion			
Operator Type:	Mull			
Configuration:	Mull			
Referenced Standard:	AAMA 450-10			
Product Rating:	Missile Level D, Wind Zone 4,DP=+/-70, 124x96 Wdth=41			
Rated Dimensions:	**Max Width:**	124 in	**Max Height:**	96 in
Linked Structural CARs:	190-1010.0			

Qualifying Test information:

Test Report No:	FTL-7403
Test Report Expiration:	5/21/2029

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY

Authorized By: Shaun Shaull 2026.04.16 08:45:15 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500

Revision History

Rev #	Date	Description
0	10/8/2013	Initial Issuance.
1	5/11/2023	Granted 3 Year Extension.
2	4/16/2026	Granted 3 Year Extension