	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1030.0
Issue Date: 12/23/2014
Revision Date: 5/24/2021
Expiration Date: 11/18/2024
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Licensee Information: PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Product Information: Model: DH5460 PVC Fin/Equal Leg Double Hung Operator Type: H Config: All Max Width: 52 Max Height: 86
--	--

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG50 1324x2192 (52x86)-Type H WTP=9.75
--	---

Qualifying Test Information:	
Test Report No:	FTL-7969/7972
Test Report Expiration:	11/18/2024


Authorized Signature:

Aaron Shultz
'00'04- 09:12:55 2021.05.24

Validation Manager

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1031.0
Issue Date: 12/23/2014
Revision Date: 5/24/2021
Expiration Date: 11/18/2024
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.



This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Product Information: Model: DH5460 PVC Fin/Equal Leg Double Hung Operator Type: H Config: All Max Width: 52 Max Height: 86
--	--


Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class LC-PG65 1324x2192 (52x86)-Type H Neg DP=70
--	--

Qualifying Test Information:	
Test Report No:	FTL-7971/7973
Test Report Expiration:	11/18/2024

Authorized Signature:

Aaron Shultz
09:14:46 2021.05.24  
'00'04-

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1032.0
Issue Date: 12/23/2014
Revision Date: 5/24/2021
Expiration Date: 11/18/2024
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.



This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Product Information: Model: DH5460 PVC Equal Leg Double Hung Operator Type: H Config: AH, GS-1/8" Ann IG Max Width: 40 Max Height: 63
--	---

Referenced Standard: AAMA/WDMA/CSA 101/IS2/A440-11	Product Rating: Class R-PG50 1016x1600 (40x63)-Type H
--	---

Qualifying Test Information:	
Test Report No:	FTL-7974
Test Report Expiration:	11/18/2024

Authorized Signature:

Aaron Shultz
09:17:00 2021.05.24  
'00'04-

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501