	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02		
		Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 1011.0
Issue Date: 10/2/2014
Revision Date: 5/24/2021
Expiration Date: 7/29/2024
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.



This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Model: 5420/5440 PVC Fixed Operator Type: FW Config: No Max Width: 96 Max Height: 63


Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-11	Class CW-PG50 2438x1600 (96x63)-Type FW WTP=10.5

Qualifying Test Information:	
Test Report No:	FTL-7959
Test Report Expiration:	7/29/2024

Authorized Signature:

Aaron Shultz
08:28:48 2021.05.24  
'00'04-

Keystone Certifications, Inc.
145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title:	Doc No: FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1017.0
 Issue Date: 11/6/2014
 Revision Date: 5/24/2021
 Expiration Date: 8/12/2024
 Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.



This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Model: 5420/5440 PVC Fixed Operator Type: FW Config: No, GS-3/16" Temp IG Max Width: 120 Max Height: 60

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-11	Class CW-PG70 3048x1524 (120x60)-Type FW

Qualifying Test Information:	
Test Report No:	FTL-7891/7895/8167/8093
Test Report Expiration:	8/12/2024

Authorized Signature:

Aaron Shultz
 08:30:34 2021.05.24  
 '00'04-

Keystone Certifications, Inc.
 145 Limekiln Rd. Suite 100B
 New Cumberland, Pennsylvania 17070
 Phone: 717-932-8500
 Fax: 717-932-8501